



SEAGULL® IV X-1, X-2 Designer Series and X-6 Drinking Water Purification Systems

General Ecology presents data from testing specifically selected to demonstrate product effectiveness in removing those contaminants most frequently encountered in water supplies. Please note that all General Ecology, Inc's test results represent performance *using actual contaminants, not substitute surrogates.*

This Performance Data Sheet shows some of the removal capabilities of the SEAGULL® IV products. It is recommended that before purchasing a water treatment unit you have your water supply tested to determine your actual water treatment needs.

Product Brand Names

- | | |
|-----------------------|---|
| Seagull IV X-1 | Drinking Water Purification System, Configuration B, F, P |
| Seagull IV X-2 | Designer Series Drinking Water Purification System, Configuration B, KB, KF |
| Seagull IV X-6 | Drinking Water Purification System |

Manufacturer

All Seagull IV Drinking Water Purification Systems are manufactured in the USA by:
General Ecology, Inc.
151 Sheree Boulevard
Exton, PA 19341-1292

Operating Conditions

	X-1	X-2	X-6
Housing Material	Stainless Steel.....	Stainless Steel.....	Stainless Steel
Cartridge	RS-1SG.....	RS-2SG.....	RS-6SG
Particle Retention	0.4 micron.....	0.4 micron.....	0.4 micron
Pressure (psig) min/max	25/125.....	25/125.....	25/125
Flow Rate (gpm @ 30 psi)	1.....	2.....	6
Average Capacity (gals)	1,000.....	2,000.....	6,000
Temp (F) min/max	33/100.....	33/100.....	33/100
pH min/max	5/9.....	5/9.....	5/9

- No electricity is required.
- Do not freeze unit.
- Flow rate and capacity will depend on operating conditions and source water characteristics.
- The cartridge should be replaced annually, when the flow rate drops to an inconvenient level or if tastes and odors should become evident.

Aesthetic Water Quality Improvement

Seagull IV Drinking Water Purification Systems also remove the following, which some individuals may find offensive in drinking water: • **Chlorine** • **Foul Tastes** • **Color** • **Foul Odors** • **Turbidity**

Test Conditions

All tests were conducted under standard operating conditions as previously stated for the rated capacity of the cartridge.

Performance Notice

These data are based on documented results from specific testing and generally are regarded as indicative of effectiveness to be expected, but are not specific claims of performance. Performance may vary due to water characteristics and system operating conditions.

Test Data

Testing was conducted for the full rated capacity using the actual contaminant listed. No Surrogates were used.

Contaminant Filtered	Influent	Effluent	Detection Level	MCL ⁺
Organic Chemicals				
1,1,2-Trichloroethane	20 ppb	ND	2 ppb	5 ppb*
1,2-Dibromomethane (EDB)	1.9 ppb	ND	2 ppb	5 ppb
1,4-Dichlorobenzene	73 ppb	ND	NSF Standard 53	5 ppb ⁺⁺
2,4,5-TP (Silvex)	30.6 ppb	ND	.05 ppb	10 ppb
2,4-D	338 ppb	ND	1 ppb	70 ppb
Aldicarb (Temik)	228 ppb	ND	1 ppb	7 ppb ⁺⁺
Carbon Tetrachloride	20 ppb	0.6 ppb		5 ppb
Chlordane	50 ppb	ND	1 ppb	20 ppb
Chlorine Residual	500 ppb	ND	50 ppb	2.5 ppm (not an MCL)
Methoxychlor	240 ppb	ND	.05 ppb	40 ppb **
P-chlorobenzene	10 ppb	ND	1 ppb	5 ppb proposed *
PCB	0.05 ppb	ND	01 ppb	--
Tetrachlorethylene (PCE)	73 ppb	ND	NSF Standard 53	5 ppb
Trichloroethylene (TCE)	328 ppb	ND	NSF Standard 53	5 ppb
Trihalomethane Total	92 ppb	ND	1 ppb	100 ppb**
ND - None Detected				

Test Data

Testing was conducted for the actual contaminant listed. No Surrogates were used.

Contaminant Filtered	Influent	Effluent	Detection Level	MCL ⁺
Microbiological				
	(colonies/100 ml)	(colonies/100 ml)	(colonies/100 ml)	(colonies/100 ml)
Campylobacter jejuni	1.6-3.0 x 10 ⁷	ND	10	--
Cryptosporidium	1 ⁻³ x 10 ⁵	ND	1	--
Escherichia coli	10 ⁷	ND	1	0/100 ml
Escherichia coli 0157:H7	10 ⁷	ND	10	0/100 ml
Fecal Coliform	10 ³	ND	1	0/100 ml
Giardia lamblia	1.13 x 10 ⁵⁺⁺⁺	ND	1	--
Listeria monocytogenes	2.2-2.8 x 10 ⁷	ND	10	--
Poliovirus and Rotavirus	6.3 x 10 ⁵ -2.8 x 10 ⁶	ND-320 pfu	11 pfu	--
Pseudomonas aeruginosa [§]	10 ³	ND	1	--
Salmonella typhi [§]	10 ⁵	ND	1	0/100 ml
Yersinia enterocolitica	2.0-2.8 x 10 ⁵	ND	10	--
ND - None Detected				

Test Data

Testing was conducted for the actual contaminant listed. No Surrogates were used.

Contaminant Filtered	Influent	Effluent	Detection Level	MCL ⁺
	<i>Original Well Water</i>	<i>Tested Filtered Water</i>		
Aesthetics				
Color	20	0	--	--
Hardness	72 mg/L	66 mg/l	--	--
Odor	abnormal	normal	--	--
Taste	abnormal	normal	--	--
Turbidity	2	0	--	--
ND - None Detected				

Extraction Data

Leaching tests comply with NSF Standard 53

Contaminant Leached	Testing Protocol	Result	Detection Level
<p>Systems have been evaluated, tested and comply with NSF/ANSI Standard 53-2010 requirements for extraction of volatiles, semi-volatiles and metal.</p>			

- ⁺ Maximum Contaminant Level of Federal Standards shown unless a more rigorous standard is indicated.
- ⁺⁺ New York Maximum Contaminant Level is more rigorous than Federal level.
- ⁺⁺⁺ Total per 500 gallons.
- [§] Sampled at less than rated capacity.
- ^{*} Journal AWWA, February 1992.
- ^{**} Water Technology, August 1991.

Note: Intended not to remove dissolved salts and minerals. Various Federal, State and Local regulations may become known or change and affect distribution and presentation of performance claims. All health claims not in compliance with local or state laws are hereby withdrawn.

